



## Certificate of Completion

### Duct Sealing Performed For:

Woodstone , Woodstone Custom Homes  
Lot 36 Stonington Ridge  
Victor, NY 14564

### Overall Sealing Results

When we arrived,  
YOUR DUCTS HAD:

**434.3 CFM of Leakage**, equivalent to a  
**82.1 Square Inch Hole**


*This equals 260.6 refrigerators full of air loss every hour.*

After we finished,  
YOUR DUCTS HAVE:

**39.6 CFM of Leakage**, equivalent to a  
**7.5 Square Inch Hole**

**This corresponds to a 90.9% Reduction in Duct Leakage.**

**Note:** Duct Leakage results are calculated in Cubic Feet per Minute (CFM) measured at a standard OPERATING PRESSURE of 25 Pa.



Aeroseal Technician **Blake**

Aeroseal Case ID **4400**

Date of Seal **5/1/2017**

System Description **Forced Air**

Seal Description **Whole House**

Hardware **HomeSeal**

### Duct Sealing Performed By:

Paris Heating and Cooling  
1383 West Ridge Road  
Rochester, NY 14615  
Phone: 585-227-4512

**AEROSEAL**<sup>®</sup>  
Duct Sealing From The Inside